

Tyba TY-K-TURN IP

Crestron module guide

The Tyba TY-K-TURN IP module is used to interact with the TY-K-TURN when setup to use IP mode (as opposed to Cresnet). This module uses SSE/HTTP commands internally, and as such requires no external TCP clients.

Required files

For the module to function correctly, the following files should be placed in either the project directory, or the central Crestron module directory:

Tyba TY-K-TURN IP (version).umc

Tyba TY-K-TURN IP (version).usp

Tyba TY-K-TURN IP (version).ush

Tyba TY-K-TURN Library v3.clz

NOTE: The clz is a compiled C# library that contains the SSE/HTTP code.

Usage – Parameters

When you drag in a new instance of the module, the first thing to do is to set the module parameters, as shown in the image below:

Sender ID\$	<enter custom ID>
IP Address\$	<enter turn IP>
Volume Scaling	65535d
Light Scaling	255d
Shade Scaling	100d
SourceType 1	Normal
SourceType 2	Normal
SourceType 3	Normal
SourceType 4	Normal
SourceType 5	Normal
SourceType 6	Normal
SourceType 7	Normal
SourceType 8	Normal
Debug Mode	On

(please see next page for parameter descriptions)

Sender ID\$

This is a string parameter that identifies the module to the SSE/HTTP layer on the TURN. This is used to ensure that commands sent from this instance of the module are not then instantly read back in again. This should be a unique identifier, such as “Bedroom Turn” or “Hallway Turn” for example.

IP Address\$

This is a string parameter that should match the IP address of the TURN unit you wish to connect to. It should be in the standard IP address format, for example “192.168.0.100”

Volume Scaling

This is an integer parameter that defines the maximum volume on the device (amplifier etc) that will be used to show volume feedback on the Turn. As every device will have a different maximum volume, this parameter is used to scale the volume into the correct range for the Turn.

Light Scaling

As with volume scaling above, this integer parameter denotes the maximum level used from the lighting system for light level feedback. KNX for example uses 0-255, whereas Crestron uses 0-65535.

Shade Scaling

As with volume/light scaling above, this integer parameter denotes the maximum level used from the shading system for shade level feedback. KNX for example uses 0-255, whereas Crestron uses 0-65535.

Source Type

Select Normal or Integrated. A normal source will update volume/media changes. Integrated will not update, as it will be updated by the integrated source (i.e. Sonos).

Debug Mode

This is a fixed list of 2 options, either On or Off. When set to On, the module will output additional debug information within Crestron Debugger, which makes it easier to find any potential control issues, such as IP disconnects etc.

Usage – Signal Groups

The input/output signals on the module are broken down into sections, to match the available functions on the Turn. These are shown in the image below:

+	System	System	+
+	Light_Scenes	Light_Scenes	+
+	Lights	Lights	+
+	Temperature	Temperature	+
+	Fan_Speeds	Fan_Speeds	+
+	Modes	Modes	+
+	Humidity	Humidity	+
+	Shade_Scenes	Shade_Scenes	+
+	Shades	Shades	+
+	Air_Quality	Air_Quality	+
+	Air_Pressure	Air_Pressure	+
+	Media	Media	+

Each of these groups contains input/output signals, which are used to receive signals from the Turn, and send back feedback such as volume/active light scene etc.

These signals are a mix of **digital/analog/serial** and are described in more detail on the following pages.

System

The System signal group contains signals for initialising the module, outputting debug information, and discrete outputs from the temperature sensor, in Celsius and Fahrenheit. The discrete Celsius/Fahrenheit will always output their values, regardless of the settings in the config. This could be used when the Turn is simply a light controller, for example, to still provide a temperature reading for house management etc. Another example could be to use these for averaging across multiple sensors in a room, even in situations when the Turn is used for something simple, like controlling lights.

Module Inputs >>>

System_Initialise – this digital signal should be pulsed on processor bootup. It sets up the module ready for usage, based on the parameters etc. It is vital to pulse this signal on bootup, for the module to function properly.

>>> Module Outputs

System_Debug_Information\$ - this serial signal can be used to trace debug information in Crestron Debugger. Whilst use of this signal is optional, it is recommended best practice to use it should any issues occur.

Discrete_Celsius – this analog signal will always output the Celsius reading of the internal temperature sensor, in hundreds; for example, 22.5 will output as 225.

Discrete_Fahrenheit – this analog signal will always output the Fahrenheit reading of the internal temperature sensor, in hundreds; for example, 66.5 will output as 665.

Discrete_Celsius\$ – this serial signal will always output the Celsius reading of the internal temperature sensor as a floating point string, for example “22.5”

Discrete_Fahrenheit\$ – this serial signal will always output the Fahrenheit reading of the internal temperature sensor, as a floating point string, for example “66.5”

(please see next page for continued signal groups)

Light_Scenes

The Light_Scenes signal group contains signals for selecting scenes, as well as signals for incrementing/decrementing the current scene, and to show whether scenes are currently on/off, including feedback signals for all.

Module Inputs >>>

Light_Scene_xx_FB (where xx = Off to 7) – these signals should be latched to display the currently selected light scene on the Turn. Only 1 of these should be latched at any one time. These signals should be tied to the scene feedback from the lighting system.

Light_Scene_Switched_On_FB/Light_Scene_Switched_Off_FB – when not using scenes, these 2 inputs can be used as absolute on/off feedback to the Turn. Only one of these signals should be high at any one time.

Light_Scene_Increment/Light_Scene_Decrement– these 2 inputs provide an option for selecting scenes on the Turn. Pulsing increment will move up the scenes by 1 position (scene_1 -> scene_2 -> scene_3). Pulsing decrement will move down the scenes by 1 position (scene_1 -> scene_2 -> scene_3).

>>> Module Outputs

Light_Scene_xx (where xx = Off to 7) – these signals will pulse as the user selects light scenes on the Turn. These should be tied to the corresponding scene signals on the lighting system.

Light_Scene_Switch_On/Light_Scene_Switch_Off – as an alternative to scenes, these 2 outputs provide an absolute on/off from the Turn. If the user turns the outer wheel all the way to the left, the off will be pulsed. If the user turns the wheel to the right, the on signal will pulse.

(please see next page for continued signal groups)

Lights

The Lights signal group contains signals for individual lighting circuits, which include an on/off for each circuit, as well as a light level, all with feedback.

Module Inputs >>>

Light_xx_Level_FB (where xx = 1 to 5) – these analog signals can be used to display the actual light level for each of the 5 circuits. The scaling used on this input relates to the parameters described on page 2. These signals should be tied to the relevant level signal from the lighting system.

Light_xx_On_FB/Light_xx_Off_FB (where xx = 1 to 5) – when not using levels, these 2 inputs can be used to show if a light circuit is currently on or off. Only one of these signals should be high at any one time.

>>> Module Outputs

Light_xx_Level (where xx = 1 to 5) – these analog signals can be used to control the level of a lighting circuit. They output a value as the user turns the outer wheel on the Turn with a lights page selected (up to 5). The range of these signals will be determined by the Light Scaling parameter as described on page 2. These signals should be tied to the relevant light level signal on the lighting system.

Light_xx_On/Light_xx_Off (where xx = 1 to 5) – these digital signals can be used as an absolute on/off when not using levels. If the user turns the outer wheel on the Turn all the way to 0% (with 1 of 5 lights selected), then the off signal will pulse. If the user turns to any value higher than 0%, then the on signal will pulse instead.

(please see next page for continued signal groups)

Shade_Scenes

The Shade_Scenes signal group contains signals for selecting shade scenes, as well as signals for incrementing/decrementing the current scene.

Module Inputs >>>

Shade_Scene_xx_FB (where xx = 1 to 8) – these signals should be latched to display the currently selected shade scene on the Turn. Only 1 of these should be latched at any one time.

Shade_Scene_On_FB/Shade_Scene_Off_FB – when not using scenes, these 2 inputs can be used as an absolute on/off feedback to the Turn. Only one of these signals should be high at any one time.

Shade_Scene_Increment/Shade_Scene_Decrement– these 2 inputs provide an option for selecting shade scenes on the Turn. Pulsing increment will move up the shade scene by 1 position (scene_1 -> scene_2). Pulsing decrement will move down the shade scene by 1 position (scene_2 -> scene_1).

>>> Module Outputs

Shade_Scene_xx (where xx = 1 to 8) – these signals will pulse as the user selects shade scenes on the Turn. These should be tied to logic that sets the various shades to pre-defined levels.

Shade_Scene_On/Shade_Scene_Off – as an alternative to scenes, these 2 outputs provide an absolute on/off from the Turn. If the user turns the outer wheel all the way to the left, the off will be pulsed. If the user turns the wheel to the right, the on signal will pulse.

(please see next page for continued signal groups)

Shades

The Shade signal group contains signals for individual shades (curtains/blinds etc), which include 2 options for control; either an analog “position” signal (for use on systems that allow for absolute blind positions), or digital open/close/stop signals.

Module Inputs >>>

Shade_xx_Position_FB (where xx = 1 to 5) – these analog signals can be used to display the actual position of each shade on the Turn. The scaling used on these inputs relates to the Shade Level parameter described on page 2. These signals should be tied to the relevant position signal from the shading system.

Shade_xx_Open_FB (where xx = 1 to 5) – on systems that do not provide a position signal for each shade, these digital signals can be used to display on the Turn that shades are open.

Shade_xx_Close_FB (where xx = 1 to 5) – on systems that do not provide a position signal for each shade, these digital signals can be used to display on the Turn that shades are closed.

Module Outputs >>>

Shade_xx_Position (where xx = 1 to 5) – these analog signals can be used to control the position of a shade. They output a value as the user turns the outer wheel on the Turn with a shade page selected (up to 5). The range of these signals will be determined by the Shade Scaling parameter as described on page 2. These signals should be tied to the relevant shade position signal on the shading system.

Shade_xx_Open (where xx = 1 to 5) – on systems that do not provide a position signal for each shade, these digital signals can be used to perform an open function on the shade. This will pulse high if the user scrolls the outer wheel on the Turn to the **left**, with a shade selected.

Shade_xx_Close (where xx = 1 to 5) – on systems that do not provide a position signal for each shade, these digital signals can be used to perform a close function on the shade. This will pulse high if the user scrolls the outer wheel on the Turn to the **right**, with a shade selected.

(please see next page for continued signal groups)

Temperature

The Temperature signal group contains signals for displaying the current room temperature and setpoint, as well as outputs for changing the setpoint from the Turn. Both analog and serial signals are available, depending on the HVAC system being used.

Module Inputs >>>

Temperature_Setpoint_FB – this analog signal can be used to display the actual temperature setpoint of the room, on the Turn. As Crestron does not use floating point numbers, this number should be in the hundreds range, for example to display 22.5 the value should be 225. This signal should be tied to the temperature setpoint analog feedback from the HVAC system.

Temperature_Setpoint_FB\$ – this serial signal can be used as an alternative to the analog signal above, to display the actual temperature setpoint of the room, on the Turn. This should be in the xx.x format (for example 22.5). This signal should be tied to the setpoint serial feedback from the HVAC system.

Temperature_Current_FB – this analog signal can be used to display the actual current temperature of the room, on the Turn, when the config is set to external temperature. As Crestron does not use floating point numbers, this number should be in the hundreds range, for example to display 22.5 the value should be 225. This signal should be tied to the temperature analog feedback from the HVAC system.

Temperature_Current_FB\$ – this serial signal can be used as an alternative to the analog signal above, to display the actual current temperature of the room, on the Turn. This should be in the xx.x format (for example 22.5). This signal should be tied to the temperature serial feedback from the HVAC system.

Temperature_Setpoint_Up – this digital signal can be used to increment the setpoint on the turn by 0.5, on systems that do not provide an output for analog/serial.

(please see next page for continued temperature signals)

Temperature_Setpoint_Down – this digital signal can be used to decrement the setpoint on the turn by 0.5, on systems that do not provide an output for analog/serial.

>>> *Module Outputs*

Temperature_Setpoint – this analog signal can be used to change the setpoint for the room on the HVAC system. When the user is on the Temperature page on the Turn, this signal will output a value as the user turns the outer wheel. As Crestron does not use floating point numbers, this number will be in the hundreds range, for example if the Turn is displaying 22.5 the value output will be 225. This signal should be tied to the analog temperature setpoint signal on the HVAC system.

Temperature_Setpoint_FB\$ – this serial signal can be used as an alternative to the analog signal above, to change the setpoint of the room on the HVAC system. This will be in the xx.x format (for example 22.5). This signal should be tied to the serial setpoint signal on the HVAC system.

Temperature_Current – this analog signal can be used to display the temperature reading from the internal sensor, when the config is set to use internal temperature. This will be in the selected format within the config, either Celsius or Fahrenheit. As Crestron does not use floating point numbers, this number will be in the hundreds range, for example 22.5(c) will be 225, or 66.5(f) will be 665. This signal will only output when the temperature page is used on the Turn. If you need internal temperature readings without using a temperature page, please refer to the discrete temperatures under the system section.

Temperature_Current\$ this serial signal can be used to display the temperature reading from the internal sensor, when the config is set to use internal temperature. This will be in the selected format within the config, either Celsius or Fahrenheit. This will be in the xx.x format, for example 22.5(c) or 66.5(f). This signal will only output when the temperature page is used on the Turn. If you need internal temperature readings without using a temperature page, please refer to the discrete temperatures under the system section.

(please see next page for continued signal groups)

Humidity

The Humidity signal group contains signals for displaying the current room humidity and setpoint, as well as outputs for changing the setpoint from the Turn. Both analog and serial signals are available, depending on the HVAC system being used.

Module Inputs >>>

Humidity_Setpoint_FB – this analog signal can be used to display the actual humidity setpoint of the room, on the Turn. As Crestron does not use floating point numbers, this number should be in the hundreds range, for example to display 22% the value should be 220. This signal should be tied to the humidity setpoint analog feedback from the HVAC system.

Humidity_Setpoint_FB\$ – this serial signal can be used as an alternative to the analog signal above, to display the actual humidity setpoint of the room, on the Turn. This should be in the xx format (for example 22). This signal should be tied to the humidity setpoint serial feedback from the HVAC system.

Humidity_Setpoint_Up – this digital signal can be used to increment the humidity setpoint on the turn by 1%, on systems that do not provide an output for analog/serial.

Humidity_Setpoint_Down – this digital signal can be used to decrement the humidity setpoint from the turn by 1%, on systems that do not provide an output for analog/serial.

>>> Module Outputs

Humidity_Setpoint – this analog signal can be used to change the humidity setpoint for the room on the HVAC system. When the user is on the Humidity page on the Turn, this signal will output a value as the user turns the outer wheel. As Crestron does not use floating point numbers, this number will be in the hundreds range, for example if the Turn is displaying 22% the value output will be 220. This signal should be tied to the analog humidity setpoint signal on the HVAC system.

(please see next page for continued humidity signals)

Humidity_Setpoint_FB\$ – this serial signal can be used as an alternative to the analog signal above, to change the humidity setpoint of the room on the HVAC system. This will be in the xx.x format (for example 22.5). When the user is on the Humidity page on the Turn, this signal will output a value as the user turns the outer wheel. This signal should be tied to the serial humidity setpoint signal on the HVAC system.

Fan Speeds

The Fan Speeds signal group contains signals for selecting fan speeds, as well as signals for incrementing/decrementing the current speed, and to show whether fans are currently on/off, including feedback signals for all.

Module Inputs >>>

Fans_Off_FB – this digital signal should be latched to display that fans are off on the turn. This signal should be tied to the fans off feedback from the HVAC system.

Fans_xx_FB (*where xx = 1 to 8*) – these signals should be latched to display the currently selected fan speed on the Turn. Only 1 of these should be latched at any one time, unless Fans_Off_FB is latched, in which case none of these should be. These signals should be tied to the fan speed feedback from the HVAC system.

Fans_Switched_On_FB/Fans_Switched_Off_FB – these 2 signals can be used as an absolute fans on/off feedback to the Turn when individual speeds are not being used. Only one of these should be high at any one time.

Fans_Increment/Fans_Decrement– these 2 inputs provide an alternative option for changing fan speeds on the Turn. Pulsing these will increment/decrement the fanspeed on the Turn by 1 speed.

(please see next page for continued fan signals)

>>> *Module Outputs*

Fans_Off – this digital signal will pulse when the user selects off on the Turn when on the fans page. Should be tied to the fans off signal in the HVAC system.

Fans_xx (*where xx = 1 to 8*) – these signals will pulse as the user selects fan speeds on the Turn. These should be tied to the corresponding fan speed signals on the HVAC system.

Fans_Switch_On/Fans_Switch_Off – these 2 inputs provide an absolute on/off for the fan speeds from the Turn. If the user moves the outer wheel all the way to the left, the off signal will pulse. If the user moves the outer wheel to the right, the on signal will pulse.

Modes

The Modes signal group contains signals for selecting HVAC modes, as well as signals for incrementing/decrementing the current mode, including feedback signals for all.

Module Inputs >>>

Modes_xx_FB (*where xx = 1 to 8*) – these signals should be latched to display the currently selected HVAC mode on the Turn. Only 1 of these should be latched at any one time. These signals should be tied to the HVAC modes feedback from the HVAC system.

Modes_Switched_On_FB/Modes_Switched_Off_FB – these 2 signals can be used as an absolute modes on/off feedback to the Turn when individual modes are not being used. Only one of these should be high at any one time.

Modes_Increment/Modes_Decrement– these 2 inputs provide an alternative option for changing modes on the Turn. Pulsing these will increment/decrement the mode on the Turn by 1.

(please see next page for continued mode signals)

>>> *Module Outputs*

Modes_Off – this digital signal will pulse when the user selects the lowest mode on the Turn when on the modes page. Should be tied to the relevant mode signal in the HVAC system.

Modes_xx (*where xx = 1 to 8*) – these signals will pulse as the user selects HVAC modes on the Turn. These should be tied to the corresponding mode signals on the HVAC system.

Modes_Switch_On/Modes_Switch_Off – these 2 inputs provide an absolute on/off for the modes from the Turn. If the user rotates the outer wheel all the way to the left, the off signal will pulse. If the user rotates the outer wheel to the right, the on signal will pulse.

Media

The Media signal group contains signals for showing play/pause status of the currently selected source, showing whether the audio is currently muted or not, volume level and increment, selecting sources and system off, and displaying source artwork and metadata.

Module Inputs >>>

Play/Pause_FB – this digital signal should be buffered from the currently selected source (where available), and will change the play/pause icon on the Turn depending on its state; high will show the playing icon , low will show the pause icon.

Mute_FB – this digital signal should be held high when the audio is muted, to show the mute on icon on the Turn. When low the un-muted signal will be displayed on the Turn.

Prev/Next_FB – these digital signals can be buffered from the currently selected source (where available) but are optional.

(please see next page for continued media signals)

Volume_FB – this analog signal can be used to display the actual volume in the room and uses the Volume Scaling parameter as shown on page 2. This should be tied to the volume feedback signal from the amplifier (etc).

Volume_Increment/Volume_Decrement– these 2 inputs can be used when direct volume level feedback is not available. Pulsing these will increment/decrement the volume on the Turn by 1%.

System_Off_FB – this digital input can be used to set the AV page to an off state, clearing any artwork and metadata.

Select_Source_xx_FB (*where xx = 1 to 8*) – these digital inputs can be used to select one of the 8 sources on the AV page.

Source_Artwork_FB\$ – this serial input can be used to display artwork on the AV page, by sending in the URL of an image.

Source_Metadata_1_FB\$ – this serial input can be used to display a line of meta-data on the first line of the AV page, such as playing track name.

Source_Metadata_2_FB\$ – this serial input can be used to display a line of meta-data on the second line of the AV page, such as playing artist name.

>>> Module Outputs

Play/Pause – this digital signal can either be tied directly to the Play/Pause signal of the currently selected device, or where available, should be buffered to the direct Play and Pause, depending on the Play/Pause state of the source.

Prev – this digital signal will pulse as the user presses previous on the Turn display whilst on the Media page. Should be tied to the prev/rew (etc) signal of the currently selected source.

Next – this digital signal will pulse as the user presses next on the Turn display whilst on the Media page. Should be tied to the next/ffwd (etc) signal of the currently selected source.

(please see next page for continued Media signals)

Volume – this analog signal will output a value as the user moves the outer wheel on the Turn when on the Media page. This will be scaled according to the Volume Scaling parameter as shown on page 2. This should be tied directly to the volume level input of the rooms amplifier (etc).

System_Off – this digital output will pulse when the user presses the system off button on the Media page.

Select_Source_xx (*where xx = 1 to 8*) – these digital inputs will pulse when the user selects one of the 8 sources on the Media page.

Air Quality/Pressure

The air quality/pressure signal groups contain signals for showing air quality/pressure on the Turn; this can either be a level (analog), a message (serial).

>>> Module Inputs

Air_Quality/Pressure_FB – these analog signals can be used to display an info level on the Turn. Air quality, displayed as ppm, air pressure is displayed as pa.

Air_Quality/Pressure_FB\$ – these serial signals can be used to display an info level on the Turn. Air quality, displayed as ppm, air pressure is displayed as pa.

SSE/HTTP

This IP version of the TY-K-TURN module uses SSE/HTTP internally, using a compiled C# library. When a signal is sent to the Turn, it is achieved using a HTTP post command, so there is no need for a constantly active TCP connection. Alternatively, if the Turn sends signals back, these are read in using SSE (server side events). The C# library will sit in a non-blocking thread, waiting for new commands to be posted. As such, not constant polling or active TCP connection is required; the module will effectively “sleep” until a new command is posted by the Turn.